




# 水静压试验报告

## Hydraulic Test Report

QJ/DNB08.01-63

No.

型号 Type	PC40-2250-25	零件名称 Item	泵体/泵盖 Pump Casing Casing Cover	零件标识 Identification of part	2017-G001-3 P-1203A
序号 No	水静压试验要求 Hydraulic test requirement		实测 Actual measure		
1	试验压力值 ( 3 ) Mpa Pressure Value ( 3 ) Mpa		3.2 Mpa		
2	保压时间 ( 30 ) min Holding time ( 30 ) min		30 min		
3					
4					
5					
6					
备注: Remark	<p>无渗漏</p> <p>NO-Leakage</p> <p>试验者 (Tester): </p> <p>日期 (Date): 17.9.5</p>		<p>结论: Conclusion</p> <div style="text-align: center;">  </div> <p>检验员 (Inspector): </p> <p>日期 (Date): 17.9.5</p>		